

Full-scale implementation of external nitrification biological nutrient removal at the Daspoort Waste Water Treatment Works

AW Muller¹, MC Wentzel^{1*}, GB Saayman², SA van de Merwe², CM Esterhuysen², JS Snyman² and GA Ekama¹

¹Water Research Group, Department of Civil Engineering, University of Cape Town, Rondebosch 7701, South Africa

²Daspoort Waste Water Treatment Works, City of Tswane Metropolitan Municipality, PO Box 1409, Pretoria 0001, South Africa

Abstract

In the external nitrification (EN) biological nutrient removal (BNR) activated sludge (AS) system, the nitrification process is removed from the main BNRAS system to a fixed media system external to the AS system (Hu et al., 2003). The ENBNRAS system provides considerable advantages over the conventional BNRAS system, e.g. reduced bioreactor volumes, secondary settling tank surface area and oxygen demand. Further, the ENBNRAS system provides opportunity for substantial system intensification. The performance and characterization of the ENBNRAS system has been successfully demonstrated at lab-scale (Hu et al., 2000, Söttemann et al., 2002), but has not yet been tested in full-scale implementation. In collaboration between the City of Tshwane Metropolitan Municipality (CTMM) and the University of Cape Town, ENBNR activated sludge is being implemented at full-scale at the Daspoort Waste Water Treatment Works (DWWTW) in Central Pretoria, South Africa. This paper describes the preliminary design of this full-scale plant and initial implementation.

Introduction

In the external nitrification (EN) biological nutrient removal (BNR) activated sludge (AS) system, the nitrification process is removed from the main BNRAS system to a fixed media system external to the AS system (Hu et al., 2003). This resolves the two main constraints of conventional BNRAS systems, i.e. the long sludge age requirement for nitrification and the difficulty in achieving near complete nitrogen removal. Specifically, the sludge age of the system can successfully be reduced from typically 20–25 days in conventional BNRAS systems to 8–10 days in the ENBNRAS system, resulting in a 30% reduction in the activated sludge system volume required (Hu et al., 2000). Additionally, the aerobic mass fraction can be reduced from 50–60%, to less than 30% in the ENBNRAS system, and, concomitantly, the anoxic mass fraction can be increased from 25–35% to 55% (anaerobic mass fraction of 15%). The increase in anoxic mass fraction, together with the fact that nitrification precedes denitrification in the system layout, enables the possibility of near complete denitrification. Moving nitrification to the fixed media system and the increased denitrification significantly reduce (by 2/3rds) the oxygen requirements in the ENBNRAS system compared to the conventional BNRAS system. Further, the ENBNRAS system requires significantly reduced secondary settling tank surface area due to likely amelioration of anoxic-aerobic (AA, or low F/M) filamentous bulking (Casey et al., 1994). Thus, the ENBNRAS system provides opportunity for substantial system intensification. The performance and characterization of the ENBNRAS system has been

successfully demonstrated at lab-scale (Hu et al., 2000, Söttemann et al., 2002), but has not yet been tested in full-scale implementation. In collaboration between the City of Tshwane Metropolitan Municipality (CTMM) and the University of Cape Town, ENBNR activated sludge is being implemented at full-scale at the Daspoort Waste Water Treatment Works (DWWTW) in Central Pretoria, South Africa.

This paper describes the design and initial implementation of full-scale external nitrification biological nutrient removal (ENBNR) activated sludge at the Daspoort Waste Water Treatment Works (DWWTW) operated by the City of Tshwane Metropolitan Municipality (CTMM) in Central Pretoria, South Africa. It presents a general description of the DWWTW, an overview of the main elements in the initial evaluation of DWWTW as a candidate site for EN implementation, and a summary of current performance of the EN system at DWWTW.

Daspoort Waste Water Treatment Works plant description

A detailed description of the Daspoort Waste Water Treatment Works (DWWTW) prior to implementation of the ENBNR activated sludge system is presented by WMB and Bigen Africa (2000). In brief, the DWWTW is located on the southern banks of the Apies River on the north-western edge of the Pretoria Central Business District (CBD). Wastewater from the Central Pretoria area is collected in a main outfall sewer that runs alongside the Apies River past the DWWTW to the Rooiwal Waste Water Treatment Works (RWWTW). The DWWTW abstracts raw wastewater from this outfall sewer at two points, to be treated in its older “Eastern” Works, and newer “Western” Works respectively. The influent flows drawn from both locations are controlled by automatic sluice gates maintaining an approximately constant influent flowrate to DWWTW.

The influent wastewater to both Works at DWWTW undergo mechanical screening, grit removal and primary settling in Dort-

This paper was originally presented at the 2004 Water Institute of South Africa (WISA) Biennial Conference, Cape Town, South Africa, 2-6 May 2004.

* To whom all correspondence should be addressed.

☎+2721 650-2583.; fax: +2721 689-7471;

e-mail: markw@eng.uct.ac.za




Figure 2

Proposed configuration for ENBNR activated sludge system at Daspoort Waste Water Treatment Works (DWWTW), with Compartment 7 anoxic

Settled sewage influent parameter	Symbol	Value	Unit
Influent flowrate	Q_i	14	M ℓ /d
COD concentration	S_{ti}	320	mgCOD/ ℓ
Unbiodegradable particulate fraction	f_{up}	0.04*	COD/COD
Unbiodegradable soluble fraction	f_{us}	0.10*	COD/COD
TKN concentration	N_{ti}	35.8	mgN/ ℓ
Ammonia concentration	N_{ai}	19.5	mgN/ ℓ
Nitrate concentration	NO_3	0.0	mgN/ ℓ
Ortho-P concentration	PO_4	4.5	mgP/ ℓ
Total-P concentration	P_{ti}	5.8	mgP/ ℓ

Activated sludge characteristic	Symbol	Value	Unit
Sludge age	R_s	11	d
Measured MLSS concentration	X_{tm}	3.5	gTSS/ ℓ
Mass of MLSS in Module 9	MX_{tm}	24000	kgTSS
MLVSS/MLSS ratio	f_i	0.85	VSS/TSS
Dilute sludge volume index	DSVI	160	m ℓ /g

returned to the first primary anoxic compartment (Compartment 4). The mixed liquor from the last aerobic compartment (Compartment 9) would overflow a weir to the 2 existing SSTs. The RAS (underflow) from the SSTs would be discharged to the pre-anoxic compartment (first 1/3 of Compartment 1).

Influent wastewater and activated sludge characteristics

As described above, the BNRAS system of Module 9 would receive settled sewage from vertical flow Dortmund primary settling tanks (PSTs). The average settled sewage characteristics for the period January 2000 – April 2002 were used in the design evaluation, with

assumed values of 0.10 and 0.04 for the unbiodegradable soluble and particulate COD fractions respectively, and are summarised in Table 2. The average values for the process characteristics for the BNRAS system used in the design were obtained by direct measurement, theoretical estimation and reasonable assumption. As a check, the measured mixed-liquor (ML) total suspended solids (TSS) concentration in the system was compared with that predicted by the Steady-State theory of Marais and Ekama (1976). The predicted mass of mixed-liquor suspended solids (MLSS) in the system (9 600 kgTSS) was substantially less than that measured (24 000 kgTSS, at 3.5 gTSS/ ℓ), which introduced significant uncertainty to subsequent determinations. To be conservative, it was decided to use the measured MLSS value of 3.5 gTSS/ ℓ in the design (this concentration is used to determine the surface areas of the ISTs and SSTs, see below). The design values used are summarised in Table 3.

Process design

The process design for EN implementation was based on the DWWTW system characteristics described above. The key points in the design are summarised below, for details see Muller et al. (2003).

Selection of influent and RAS recycle flowrates

The design evaluation estimated the capacity of the nitrifying trickling filters (NTFs) of Modules 5-6 to be approximately 347 kgN/d assuming a conservative nitrification rate of 1 gN/m²/d for the rock media NTFs (media volume of 7714 m³ at 45 m²/m³ surface area). However, the expected influent free-and-saline-ammonia (FSA) load to be nitrified on the NTFs is approximately 406 kgN/d at an influent flow rate of 14 M ℓ /d. Hence, it was recommended that the maximum influent flowrate for the design be reduced to 10 M ℓ /d; this gave FSA and TKN loads on the TFs less than their capacity. This determination corresponds with a RAS recycle ratio (R) of 0.5:1 with respect to the plant influent flow (Q), which was set at a low value to minimise the hydraulic load on the ISTs, see below.

Evaluation of internal settling tank (IST) capacity

The design evaluation determined that the modified Dortmund ISTs would be the hydraulic bottleneck in the system. Each Dortmund tank measures 13 m in diameter at its weir elevation, and is equipped with a 2m diameter vertical inlet pipe located in its centre. The tank diameter at the bottom of the inlet pipe is estimated at approximately 9m. This gives respective net overflow surface areas of 129.5 and 60.5 m² at the weir and inlet pipe discharge elevations respectively for each tank, corresponding to total system IST surface areas of 518 and 242 m² respectively. By adjusting the measured MLSS concentration of 3.5 gTSS/ ℓ to 2.5 gTSS/ ℓ to take account of the reduced influent flow of 10 M ℓ /d for the design, the theoretical relationships of Ekama et al. (1997) and Ekama and Marais (1986) were applied to estimate sludge settling velocities and maximum overflow rates allowable in the ISTs. On this basis the design determined that for the measured sludge DSVI of 160 m ℓ /g, and designed influent and RAS flowrates of 10 and 5 M ℓ /d,

respectively, the IST would fail at an MLSS concentration of 3.5 gTSS/l and be maximally loaded for an MLSS concentration of 2.5 gTSS/l (at 3.5 and 2.5 gTSS/l, predicted sludge settling velocities (V_s) for a DSVI of 160 ml/g are 1.1 and 1.8 m/h respectively). For 15 ML/d inflow to the ISTs (inflow of 10 ML/d + RAS of 5 ML/d), and underflow and overflow rates of 3 and 12 ML/d respectively, the overflow rate is 2.1 m/h at the inlet pipe discharge (surface area of 242 m²), and 1.0 m/h at the weir elevation (surface area of 518 m²) of the ISTs. Clearly, using the smaller surface area at the inlet pipe discharge would cause the ISTs to fail for these conditions. Thus, it was recommended that the inlet pipes to the Dortmund tanks be cut at the weir elevation (to maximise the available overflow surface area), or alternatively be sealed at the bottom with feed slots cut into the side of the inlet pipe at the weir level – this would significantly increase the surface area of the ISTs and give safe operation.

Final secondary settling tanks (SSTs)

The available SST surface area for Module 9 was 212 m². This gave an overflow rate of 1.9 m/h at an influent flow rate of 10 ML/d. For this overflow rate, with flux load capacity at 75% of the flux theory (Ekama et al., 1997) the DSVI must be < 140 ml/g. However, the average DSVI measured was 160 ml/g. This implies that the DSVI must improve to prevent failure of the SSTs. A significant improvement in DSVI can be expected with implementation of ENBNRAS, due to the low aerobic mass fraction (Hu et al., 2000). Thus, the available SST surface area was considered to be adequate.

Aeration capacity

For the available aeration capacity (2x45 kW in Compartments 8 and 9), the highest influent COD concentration that can be treated is 500 mgCOD/l. Since the measured settled sewage COD concentration is significantly less, at 320 mgCOD/l, the available aeration capacity was adequate.


Determination of the pre-anoxic reactor volume

Determination of the pre-anoxic volume was prepared subsequent to the initial design, see Muller et al. (2003). Based on average MLSS and estimated RAS recycle rates, it was recommended that the pre-anoxic reactor volume be 1/3 of Compartment 1, or approx. 250 m³, with the balance of Compartment 1 as anaerobic (Fig. 2).

Summary of design recommendations for the full-scale implementation of EN

In summary, the design evaluation recommended the following for implementation of ENBNRAS at DWWTW:

- Reduce the influent flow (Q_i) to 10 ML/d (with a RAS rate of 5 ML/d)
- Introduce the mixed-liquor into the ISTs at or near the weir elevation (to maximise the available overflow surface area)
- Operate the BNRAS system with a sludge age (R_s) of approximately 11 days



where:

- AN = Anaerobic zone
- AX = Anoxic zone
- AE = Aerobic zone
- pAX = Pre-anoxic zone
- NTF = Nitrifying trickling filter
- IST = Internal settling tank
- SST = Secondary settling tank
- Q = Flowrate
- P = Pump, with numbered reference

with subscripts:

- i = influent
- R = return activated sludge (RAS)
- w = waste activated sludge (WAS)
- a = internal AE to AX recycle (The dashed line indicates a temporary condition).
- e = effluent
- l = IST "liquid" overflow transfer to NTF
- b = IST sludge underflow "bypass" to main AX zone

Figure 3

Schematic diagram of the external nitrification (EN) system implemented at Daspoort Waste Water Treatment Works (DWWTW)

- Maintain a system mixed-liquor suspended solids (MLSS) concentration of approximately 2.5 g/l; the expected MLSS is much lower, at about 1.5 g/l
- Maintain the DSVI \leq 140 ml/g.

Implementation of external nitrification at DWWTW

Layout of the DWWTW external nitrification system

Retrofitting of Modules 5-6 and 9, and installation of new equipment at DWWTW, began in late 2002 and was sufficiently completed by 18 August 2003 for the ENBNRAS activated sludge system to be placed in-service. A process diagram of the ENBNRAS system as implemented at DWWTW is shown in Fig. 3; Fig. 3 shows newly purchased and installed pumps (P1 – P7) as well as existing a-recycle and RAS pumps (P8 and P9 respectively). The rated capacities and applicable flow streams of the new pumps are listed in Table 4.

Pump(s)	Flow Stream	Design ℓ/s (M ℓ /d)	Installed ℓ/s (M ℓ /d)	Actual ℓ/s (M ℓ /d)
P1	ML from AN zone to IST	175 (15)	175 (15)	120 (10)
P2-P5	IST underflow bypass to AX	60 (5)	60 (5)	40 (3.5)
P6	IST liquid overflow to NTF	120 (10)	175 (15)	N/A
P7	NTF effluent to AX	120 (10)	175 (15)	N/A




Figure 4
Mixed-liquor suspended solids (MLSS) trends at Daspoort Waste Water Treatment Works (DWWTW) for June – December 2003

Start-up of the external nitrification system at DWWTW

Operation of the ENBNRAS system at Daspoort was initiated on 18th August 2003. Operational and sampling strategies for start-up were finalised in October and are contained in Muller et al. (2003). A conservative approach was adopted in the start-up strategies to account for operational constraints within the system and limited staff availability. In brief, the start-up period was defined as the transition from the original (conventional) BNRAS operating mode to the final ENBNRAS system configuration. It was recommended to achieve the ultimate (design) ENBNRAS configuration in the three phased approach summarised below:

Phase I: Transfer of nitrification from the activated sludge process to the nitrifying trickling filters (NTFs)

The main goal in Phase I of the start-up period is the effective transfer of complete nitrification from the suspended media activated sludge aerobic (AE) zone to the fixed media nitrifying trickling filters (NTFs): In the configuration prior to ENBNRAS implementation, namely the 3-stage Bardenpho, nitrification would have occurred in the aerobic zone of the system since nitrifiers were supported in this system (larger aerobic mass fraction and longer sludge age); for successful implementation of ENBNR, this nitrification needs to virtually completely transferred to the NTFS.

Before nitrification transference takes place, (i) the nitrate load to the main anoxic reactor will be inadequate, (ii) nitrification in the main aerobic reactor will cause high nitrate loads to the pre-anoxic reactor, which may exceed this reactor's denitrification potential and cause nitrate to enter the anaerobic reactor, to the detriment of P removal, and (iii) if nitrification is lost in the AS part of the system before it establishes in the NTFS, the effluent ammonia concentrations will be unacceptably high. During the transition from AS to NTF nitrification, it is recommended that the a-recycle from the aerobic to anoxic zones be retained, to maintain a nitrate load to the primary anoxic reactor.

The essential criteria to determine if Phase I has been successfully achieved, is a NTF effluent ammonia concentration consistently < 3 mgN/l, with the Phase I N load to the NTFS ($Q_i = 5$ M ℓ /d, RAS rate = 5 M ℓ /d, IST overflow rate = 7.5 M ℓ /d and IST bypass rate = 2.5 M ℓ /d). With the achievement of this goal, the a-recycle can be removed and aeration in Compartment 7 stopped.

Phase II: Achieve successful sludge settleability in the EN system

The main goal in Phase II is to achieve good sludge settleability in the BNRAS part of the system. Good sludge settleability is essential for successful operation of the ISTs. The essential criteria to assess completion of Phase

II is a consistent DSVI < 100 m ℓ /g. With this goal achieved, the load to the system can be increased to the design 10 M ℓ /d ($Q_i = 10$ M ℓ /d, RAS rate = 5 M ℓ /d, IST overflow rate = 11.25 M ℓ /d and IST bypass rate = 3.75 M ℓ /d).

Phase III: Implement the final design configuration for the EN system at DWWTW

The main goal in Phase III is to implement the ultimate (final) design conditions (i.e. design loadings, recycle rates etc.) for the EN system at DWWTW. The essential criteria to assess attainment of Phase III is consistent overall system performance (i.e. stable TSS, VSS, DSVI, effluent values etc.).

Current performance of the external nitrification system

Operation of the ENBNRAS system at DWWTW is currently in the start-up phases. Since system initiation in August, numerous equipment failures and process disruptions have occurred which required various operational interventions to safeguard overall performance of the plant. By necessity, these operational changes were implemented frequently and often simultaneously, making systematic evaluation of resultant effects difficult. Despite this uncertainty, the following data is presented as a basic indication of current ENBNRAS system performance at DWWTW.

Mixed-liquor suspended solids (MLSS) trend

The concentration of mixed-liquor suspended solids (MLSS) in the parallel activated sludge Modules 9, 10 and 11 for June – December 2003 are shown in Fig. 4.

Daspoort WCW DSVI Trends for October - December 2003




Figure 5
Dilute sludge volume index (DSVI) trends from Modules 9, 10 and 11 at Daspoort Waste Water Treatment Works (DWWTW) for October – December 2003

From Fig. 4, the MLSS in Module 9 has varied widely since August, but appears to have stabilised at 1 360 mgTSS/ℓ since early November. This is significantly less than the recommended operating MLSS of 2 500 mgTSS/ℓ, but close to the theoretically expected value of 1 500 mgTSS/ℓ, which indicates reasonable control of sludge age - (see **Summary of Design Recommendations for the Full-Scale Implementation of EN** above).

Sludge settleability

As a measure of sludge settleability, the diluted sludge volume index (DSVI) of the parallel activated sludge Modules 9, 10 and 11 for October 2003 are shown in Fig. 5.

The mixed-liquor DSVI in Module 9 averaged 182 ml/gTSS for October 2003 and is currently 212 ml/gTSS (November – December 2003). This is significantly higher than the 140 ml/gTSS recommended in the design evaluation, and is similar to the October average for Module 11 (200 ml/g). Until significant reduction in DSVI is achieved, Phase II goals cannot be met and Phase III implemented.

As mentioned previously, however, several equipment failures and process disruptions occurred since system initiation in August. To establish consistency in system operation, the following operational changes were implemented in December: the influent flow to the ENBNRAS system was reduced from 10 to 5 Mℓ/d, the a-recycle between the aerobic and primary anoxic reactors was reactivated, and the number of in-service downstream process units were reduced by half – i.e. the ISTs from 4 to 2, the SSTs from 2 to 1 and the NTFs from 4 to 2. Since the influent to the NTFs are directly impacted by these changes, only NTF influent data after these changes (December 9 – 23, 2003) are included in Table 5. It should be noted, therefore, that consequently the data set is still small and thus insufficient for more detailed analysis.

Nitrification performance of the nitrifying trickling filters (NTFs)

A summary of average settled sewage and NTF influent wastewater for the period 19 November to 23 December 2003 is presented in Table 5. Each day's values were evaluated within the data set 95% confidence interval, with those lying outside this interval ($\approx \text{mean} \pm 1.96 \times \text{sample standard deviation}$) rejected as outliers.

As mentioned previously, however, several equipment failures and process disruptions occurred since system initiation in August. To establish consistency in system operation, the following operational changes were implemented in December: the influent flow to the ENBNRAS system was reduced from 10 to 5 Mℓ/d, the a-recycle between the aerobic and primary anoxic reactors was reactivated, and the number of in-service downstream process units were reduced by half – i.e. the ISTs from 4 to 2, the SSTs from 2 to 1 and the NTFs from 4 to 2. Since the influent to the NTFs are directly impacted by these changes, only NTF influent data after these changes (December 9 – 23, 2003) are included in Table 5. It should be noted, therefore, that consequently the data set is still small and thus insufficient for more detailed analysis.

NTF effluent values are similarly few, but are presented in Table 6. Furthermore, as mentioned earlier, one NTF Module (Module 6) was placed out-of-service in December, thus the average NTF effluent values in Table 6 are for Module 5 only.

On average, therefore, approximately 97% of influent free-and-saline ammonia (FSA) to Module 5 is nitrified. This translates

TABLE 5

Average settled and NTF influent wastewater values for 19 November – 23 December 2003 (AVG = average; SSD = sample standard deviation; N = number of data)

Parameter	Unit	Settled wastewater			NTF Influent		
		AVG	SSD	N	AVG	SSD	N
pH	-	7.42	0.06	9	7.15	0.07	6
Temp.	°C	25.3	0.9	9	24.5	0.4	6
COD	mgCOD/ℓ	281	29	8	45	9	6
TKN	mgN/ℓ	39.5	4.8	9	8.26	2.05	6
TSS	mgTSS/ℓ	-	-	-	12.5	5.6	6
FSA	mgN/ℓ	34.0	2.5	9	6.3	2.28	6

TABLE 6

Average NTF effluent values for Module 5 for December 9 – 23, 2003 (AVG = average; SSD = sample standard deviation; N = number of data)

Parameter	Unit	NTF effluent		
		AVG	SSD	N
pH	-	8.06	0.2	6
Temp.	°C	23.8	0.6	6
COD	mgCOD/ℓ	24	4	6
TKN	mgN/ℓ	2.52	1.21	6
TSS	mgTSS/ℓ	12.3	6.1	6
FSA	mgN/ℓ	0.19	0.15	6
NO ₃	mgN/ℓ	9.88	4.88	6
NO ₂	mgN/ℓ	8.67	3.88	6

into roughly 42.2 kgN/d for an average influent flow of approximately 6.9 Mℓ/d to Module 5, which gives an apparent surface specific nitrification rate of about 0.24 gN/m²/d (or volumetric nitrification rate of 10.9 gN/m³) for the 2 rock media trickling filters of Module 5. The corresponding wetting rate is about 0.746 m/h on average. Unfortunately no similar applications (optimised for nitrification only) of rock media trickling filters were found in the literature for comparison. However, although not directly comparable due to higher oxygen transfer rates and subject to different operating conditions (e.g. temperature, hydraulic loading rate, extent of media predation), several plastic media trickling filters in tertiary treatment applications were found, which suggest apparent surface specific nitrification rates of 0.39 (Boller and Gujer, 1986), 1.24 (Parker et al., 1989) and 1.6 (Parker et al., 1995) gN/m²/d among others. It would appear, therefore, that, while the DWWTW Module 5 NTFs are nitrifying successfully (97% FSA removal), the rate of nitrification per m² of surface area is still relatively low, probably due to the recent startup. This will be monitored during future research and updated in the conference presentation.

Conclusion

In conclusion, the initial design evaluation for implementing ENBNRAS at DWWTW recommended:

- Reduce the influent flow (Q_i) to 10 Mℓ/d (with a return sludge rate of 5 Mℓ/d)
- Introduce the mixed-liquor into the ISTs at or near the weir elevation (to maximise the available overflow surface area)
- Operate the BNRAS system with a sludge age (R_s) of approximately 11 days
- Maintain a system mixed-liquor concentration (X_i) of approximately 2.5 g/ℓ
- Try to keep the DSVI \leq 140 mℓ/g.

The ENBNRAS system at DWWTW was started-up on the 18th August 2003. Operating and sampling strategies for the start-up period were prepared and distributed in October. Since process initiation, numerous equipment failures and operational interventions resulted in unquantifiable effects to the process. Additionally, the lack of sufficient data at the present time prevents characterisation of the system behaviour and interpretation of the system performance with confidence. However, despite high DSVI values in the ENBNRAS system currently, preliminary results for the rock media TFs indicate the successful onset of nitrification (97% ammonia removal efficiency) although the apparent surface specific nitrification rate is still relatively low (0.24 gN/m²/d).

Acknowledgements

This research was supported by the Water Research Commission, Water Sanitation Services South Africa, a subsidiary of Ondeo Services, the Department of Trade and Industry through its Technology and Human Resources in Industry Programme (THRIP), the National Research Foundation and the University of Cape Town, and is published with their permission.

References

- BOLLER M and GUJER W (1986) Nitrification in tertiary trickling filters followed by deep-bed filters. *Water Res.* **20** (11) 1363-1373.
- CASEY TG, WENTZEL MC, EKAMA GA, LOEWENTHAL RE and MARAIS GvR (1994) An hypothesis for the cause and control of anoxic-aerobic (AA) filament bulking in nutrient removal activated sludge systems. *Water Sci. Technol.* **29** (7) 203-212.
- EKAMA GA and MARAIS GvR (1986) Sludge settleability and secondary settling tank design. *Water Pollut. Control* **86** (2) 100-113.
- EKAMA GA, BARNARD JL, GÜNTHERTFW, KREBSP, MCCORQUODALE JA, PARKER DS and WAHLBERG EJ (1997) Secondary Settling Tanks: Theory, Modelling, Design and Operation. IWA Scientific and Technical Report No. 6, IWA, Duchess House, 20 Masons Yard, Duke Street, St. James's, London SW1Y 6BU, England.
- HU ZHI-RONG, SÖTEMANN S, MOODLEY R, WENTZEL MC and EKAMA GA (2003) Experimental Investigation of the External Nitrification Biological Nutrient Removal Activated Sludge (ENBNRAS) System. *Biotechnol. and Bioeng.* **83** 260-273.
- HU ZHI-RONG, WENTZEL MC and EKAMA GA (2000) External nitrification in biological nutrient removal activated sludge systems. *Water SA* **26** (2) 225-238.
- MARAIS GvR and EKAMA GA (1976) The activated sludge process Part I – Steady-state behaviour. *Water SA* **2** (4).
- MULLER AW, SÖTEMANN SW, WENTZEL MC, EKAMA GA, SAAYMAN G, ESTERHUYSE K and SNYMAN K (2003) Practical implementation of external nitrification (EN) in biological nutrient removal activated sludge (BNRAS) systems. Progress Report April 2001 – December 2003 to the Water Research Commission and Water and Sanitation Services SA (Pty) Ltd on Contract No. K5/1262. Dept. Civil Eng., Univ. of Cape Town, Rondebosch 7701, South Africa.
- PARKER D, LUTZ M, ANDERSSON B and ASPEGREN H (1995) Effect of operating variables on nitrification rates in trickling filters. *Journal WPCF* **61** (5).
- PARKER D, LUTZ M, DAHL R and BERNKOPF S (1989) Enhancing nitrification rates in nitrifying trickling filters through biofilm control. *Water Environ. Res.* **67** (7).
- SÖTEMANN SW, VERMANDE SM, WENTZEL MC and EKAMA GA (2002) Comparison of the performance of an external nitrification biological nutrient removal activated sludge system with a UCT biological nutrient removal activated sludge system. *Water SA Special Edition: WISA Proceedings* 2002.
- WMB and BIGEN AFRICA (2000) Greater Pretoria Metropolitan Council Bulk Sanitation Strategy 2020: Evaluation of Strategic Options and Implementation of Best Strategy.